



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: (352) 343-9473

www.lakegovernment.com

ADDENDUM NO. 1

Date: May 11, 2012

Invitation to Bid (ITB) No. 12-0222

Lake County Cooling Tower Media Replacement

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid or proposal response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid or proposal from being considered for award.

This addendum ____ does X does not change the date for receipt of bids or proposals.

The purpose of this addendum is to provide confirming information to all potential responding vendors in association with the cited Invitation to Bid. The information provided herein summarizes discussions at the mandatory pre-bid meeting. Attendees of that meeting are noted on the County website for this solicitation.

The pre-bid conference commenced with a general review of the ITB with specific emphasis paid to various specific terms and conditions of the ITB including:

- The time frame stated for performance,
- The fact that the vendor would be responsible for payment of sales tax on all materials purchased by the vendor for inclusion in the project,
- The need to provide descriptive literature with their bid covering every item they were bidding that was not already listed in the ITB.
- The additional certification now included in regards to the County's reciprocal local preference ordinance.

It was also confirmed that this was a mandatory pre-bid conference and that bids would not be accepted from vendors that did not attend the conference. A technical overview of the project requirements was then provided with the following general information stated either by narrative or

in response to various questions:

Question 1: Regarding the scope of work for bid # 12-0222. It said to replace all air media in both cooling. Does this includes the Air intake louvers, Drift Eliminators, and of course the Fill Media (anti-fouling)?

Answer 1: Yes. Each of those items are considered air media to be replaced.

Question 2: Are we to seal the seams inside the spray chamber of the cooling towers? To stop any leaks. This was not mentioned.

Answer 2: Yes, the sealing process specified in the question is to be completed by the vendor.

Question 3: I would like to have the following manufacturer, Brentwood Industries, approved to supply the Anti fouling fill media VF 19 PLUS for the above project. They manufacture fill media for all major cooling towers, BAC, MARLEY AND EVAPCO which we have installed. All are built to cooling tower specification's and will not change the cooling tower performance.

Answer 3: That alternate is hereby approved.

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____